



# State Water Resources Control Board

## Division of Drinking Water

### Lead and Copper Tap Sample Results Reporting Form

*This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling*

Report Date: (mm/dd/yyyy)	08/15/2018
Water System Name:	City of Lodi
Water System Number:	3910004
Water System Type:	<input checked="" type="radio"/> Community <input type="radio"/> Non-Transient, Non Community
Monitoring Frequency:	<input type="radio"/> 6-month <input type="radio"/> Annual <input checked="" type="radio"/> Triennial
# of Samples Required:	30
# of Samples Reported:	38
<b>90<sup>th</sup> Percentile Level (mg/L)</b>	
Lead: <i>Action Level = 0.015 mg/L</i>	0.0017
Copper: <i>Action Level = 1.3 mg/L</i>	0.210

	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Result	
				Lead (mg/L)	Copper (mg/L)
01	7/17/18	K84 215 N. Lower Sacramento	1	ND	0.082
02	7/23/18	K28 1701 Lakeshore Drive	1	0.0022	0.034
03	7/24/18	K32 1729 Zinfandel Drive	1	ND	0.220
04	7/24/18	K41 917 Pinot Noir Drive	1	ND	0.180
05	7/24/18	K43 1049 Bradford Circle	1	ND	0.068
06	7/24/18	K80 2601 Bayberry Drive	1	ND	0.056
07	7/24/18	K81 2507 Alder Glen Drive	1	ND	0.085
08	7/24/18	K85 333 Palomar Drive	1	0.0022	0.017
09	7/24/18	K94 1029 Yuloni Drive	1	ND	0.011
10	7/24/18	K95 1011 Yuloni Drive	1	ND	0.022
11	7/24/18	K98 2633 Bayberry Drive	1	ND	0.041
12	7/24/18	K97 1001 Miwok Drive	1	ND	0.0084
13	7/24/18	K91 221 Columbia Drive	1	ND	0.014
14	7/24/18	K92 233 Columbia Drive	1	ND	0.0083
15	7/24/18	K86 315 Trinity Way	1	ND	0.014
16	7/25/18	K34 1517 Burgundy Drive	1	ND	0.072
17	7/25/18	K39 1007 Pinot Noir Drive	1	ND	0.220
18	7/25/18	K27 1617 Lakeshore Drive	1	ND	0.190
19	7/25/18	K29 1941 Lakeshore Drive	1	0.003	0.190
20	7/25/18	K89 9 Pinewood Court	1	ND	0.012

Division of Drinking Water  
Lead and Copper Tap Sample Results Reporting Form

---

**Sampling Site Change**

Each round of sampling should be conducted at the same sampling sites. If an original sampling site is not available, you should collect a tap sample from another site meeting the same Tier criteria as the original site.

You must complete/submit the **Lead and Copper Tap Sampling Site Change** form.

---

**Notification of Results**

As required by 40 Code of Federal Regulations Section 141.85(d), within 30 days of learning of the tap monitoring results, I notified the participants, by mailing or by another method approved by the State, of the lead sample results from their individual taps, provided an explanation of the health effects of lead, listed steps the consumer could take to reduce exposure to lead, provided contact information for the water utility, the maximum contaminant level goal for lead, action level for lead, and any definitions.

Notification was done on 08/15/2018 by  Direct Mail  
(date)  Posting in public area (NTNC systems only)  
 Other (please specify below) \_\_\_\_\_

---

For general information on lead and copper tap sampling, you can refer to the **SWRCB Lead and Copper Tap Sample Results Guidance Document**. If you have any questions or comments, please contact your regulating entity (Division of Drinking Water District or County Agency).

<b>SIGNATURE:</b> 	<b>DATE:</b> 08/15/2018
<b>NAME (Print):</b> Brian Longpre	<b>TITLE:</b> Laboratory Services Supervisor

Division of Drinking Water  
Lead and Copper Tap Sample Results Reporting Form

	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Result	
				Lead (mg/L)	Copper (mg/L)
21	7/25/18	K90 3 Pinewood Court	1	ND	0.0037
22	7/25/18	K83 2547 Alder Glen Drive	1	ND	0.034
23	7/25/18	K78 2511 Bayberry Drive	1	ND	0.0071
24	7/24/18	K68 238 Columbia Drive	1	ND	0.026
25	7/25/18	K44 136 Arbor Court	1	ND	0.130
26	7/25/18	K6 1720 Timberlake Circle	1	ND	0.280
27	7/25/18	K3 1828 Cape Cod Circle	1	ND	0.170
28	7/26/18	K51 1432 Keagle Way	1	ND	0.120
29	7/26/18	K52 1556 Iris Drive	1	0.015	0.210
30	7/26/18	K55 1428 Iris Drive	1	0.0017	0.460
31	7/26/18	K14 1614 Brandywine Court	1	ND	0.130
32	7/26/18	K25 1824 South Sacramento Street	1	ND	0.160
33	7/26/18	K15 1106 Brandywine Drive	1	ND	0.170
34	7/26/18	K5 1704 Cape Cod Circle	1	ND	0.041
35	7/26/18	K20 1014 Pinot Noir Drive	1	ND	0.180
36	7/26/18	K47 2506 Bayberry Drive	1	ND	0.110
37	7/26/18	K45 2526 Park West Drive	1	ND	0.014
38	7/26/18	K62 184 Rivergate Place	1	ND	0.026
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					